

## Spill Summary Report for NRC Report #816372

Report Date: 9/14/2022

Report Time: 4:01 PM EDT

## Region II Hotline Log Entry Information

Data ID: 298061

Date Of Report: 10/28/2006

NRC #: 816372

State #: 0608669

ERNS #: 201736

Material Type: Oil

Receiver: Norrell

Material / Amount: OIL, MISC: TRANSFORMER (40 GALLON(S)); POLYCHLORINATED BIPHENYLS (0 UNKNOWN AMOUNT)

Location: Street:  
 City: PLEASANTVILLE  
 County: WESTCHESTER  
 State: NY  
 Latitude:  
 Longitude:

Source of Pollution: Con Edison

Water Body: UNNAMED STREAM

State Or EPA Responded: RP Contractor

Initial EPA Action: None

Status:

URL:

## Associated Action Reports

DataID: 0147656

Date: 10/29/2006	Time: 15:08 EST	
Duty Officer/Responder Name: Norrell	NRC Report #: 816372	Hotline Log DataID: 298061
<b>Action Information</b>		
Description:		
Follow-Up:		
<b>Person Contacted</b>		
Name: PAUL DIDONATO Organization: CON EDISON Phone #: (212) 580-6763		

## NRC Spill Report

NATIONAL RESPONSE CENTER 1-800-424-8802

\*\*\*GOVERNMENT USE ONLY\*\*\*GOVERNMENT USE ONLY\*\*\*

Information released to a third party shall comply with any  
 applicable federal and/or state Freedom of Information and Privacy Laws

Incident Report # 816372

INCIDENT DESCRIPTION

\*Report taken by: MST3 KIRA JOHNSON at 14:29 on 28-OCT-06

Incident Type: FIXED

Incident Cause: NATURAL PHENOMENON

Affected Area: UNNAMED STREAM

The incident occurred on 28-OCT-06 at 12:13 local time.

Affected Medium: WATER UNNAMED STREAM

REPORTING PARTY

Name: PAUL DIDONATO  
 Organization: CON EDISON  
 Address: 128 WEST END AVENUE  
 NEW YORK, NY 10023

PRIMARY Phone: (212) 580 6763

INCIDENT LOCATION

2 RIDGEWOOD DRIVE County: WESTCHESTER

City: PLEASANTVILLE State: NY

POLE # 7

RELEASED MATERIAL(S)

CHRIS Code: OTF Official Material Name: OIL, MISC: TRANSFORMER

Also Known As:

Qty Released: 40 GALLON(S) Qty in Water: 0 UNKNOWN AMOUNT

CHRIS Code: PCB Official Material Name: POLYCHLORINATED BIPHENYLS

Also Known As:

Qty Released: 0 UNKNOWN AMOUNT Qty in Water: 0 UNKNOWN AMOUNT

DESCRIPTION OF INCIDENT

THE CALLER STATES THAT DUE TO HIGH WINDS A TRANSFORMER WAS KNOCKED DOWN AND SPILLED

40 GALLONS OF PCB-CONTAINING TRANSFORMER OIL SPILLED ONTO THE GROUND. AN UNKNOWN AMOUNT SPILLED INTO A NEARBY STREAM.

---

SENSITIVE INFORMATION

---

---

INCIDENT DETAILS

---

Package: N/A  
Building ID:  
Type of Fixed Object: TRANSFORMER  
Power Generating Facility: NO  
Generating Capacity:  
Type of Fuel:  
NPDES:  
NPDES Compliance: UNKNOWN

---WATER INFORMATION---

Body of Water: UNNAMED STREAM  
Tributary of:  
Nearest River Mile Marker:  
Water Supply Contaminated: NO

---

REPORTING PARTY

---

Type of Organization: PUBLIC UTILITY

---

SUSPECTED RESPONSIBLE PARTY

---

Name: PAUL DIDONATO  
Organization: CON EDISON  
Address: 128 WEST END AVENUE  
NEW YORK, NY 10023  
PRIMARY Phone: (212)5806763  
Type of Organization: PUBLIC UTILITY

---

IMPACT

---

Fire Involved: NO      Fire Extinguished: UNKNOWN  
INJURIES: NO      Hospitalized:      Empl/Crew:      Passenger:  
FATALITIES: NO      Empl/Crew:      Passenger:      Occupant:  
EVACUATIONS: NO      Who Evacuated:      Radius/Area:  
Damages: NO

		Hours	Direction of
<u>Closure Type</u>	<u>Description of Closure</u>	<u>Closed</u>	<u>Closure</u>
Air:	N		
Road:	N		Major Art <sub>N</sub>
Waterway:	N		
Track:	N		

Passengers Transferred: NO  
Environmental Impact: UNKNOWN

Media Interest: NONE      Community Impact due to Material: NO

---

REMEDIAL ACTIONS

---

CONTRACTOR HIRED FOR CLEAN UP  
Release Secured: YES  
Release Rate:  
Estimated Release Duration:

---

WEATHER

---

Weather: RAINY, 56°F

---

ADDITIONAL AGENCIES NOTIFIED

---

Federal: NONE  
State/Local: DEC, COUNTY DES  
State/Local On Scene: NONE  
State Agency Number: 0608669

---

NOTIFICATIONS BY NRC

---

USCG HSOC AT DHS (USCG HSOC DESK)  
28-OCT-06 14:34 (202)2828114  
CT DEPT OF EMERGENCY MGMT (COMMISSIONER)  
28-OCT-06 14:34 (860)2560800  
DOT CRISIS MANAGEMENT CENTER (PRIMARY)  
28-OCT-06 14:34 (202)3661863  
U.S. EPA II (PRIMARY)  
(732)3214370 NORREL  
FEDERAL EMERGENCY MANAGEMENT AGENCY (PRIMARY)

28-OCT-06 14:34 (800)6347084  
INFO ANALYSIS & INFRA PROTECTION (PRIMARY)  
28-OCT-06 14:34  
NATIONAL INFRASTRUCTURE COORD CTR (PRIMARY)  
28-OCT-06 14:34 (202)2829201  
NATIONAL INFRASTRUCTURE COORD CTR (INFRASTRUCTURE PROTECTION)  
28-OCT-06 14:34 (202)2829201  
NOAA RPTS FOR NY (PRIMARY)  
28-OCT-06 14:34 (206)5266344  
BUREAU TOXIC SUBSTANCE R. WILBURN (PRIMARY)  
28-OCT-06 14:34 (518)4027810  
NY STATE DEC SPILL HOTLINE (PRIMARY)  
28-OCT-06 14:34 (518)4577362  
CTDEP OIL & CHEM SPILL RESP DIV (PRIMARY)  
28-OCT-06 14:34 (860)4243338  
NJ DEP POC: DUTY OFFICER (PRIMARY)  
28-OCT-06 14:34 (609)5882848  
USCG DISTRICT 1 (COMMAND CENTER)  
28-OCT-06 14:34 (617)2238555

---

ADDITIONAL INFORMATION

THE CALLER HAD NO ADDITIONAL INFORMATION.

---

\*\*\* END INCIDENT REPORT # 816372 \*\*\*

Report any problems or Fax number changes by calling 1-800-424-8802

PLEASE VISIT OUR WEB SITE AT <http://www.nrc.uscg.mil>